
Power supply for comfortDIM systems (DALI protocol) for DIN rail

DALI PS






Central DALI power supply rated at 200 mA (DALI standard allows

max. 250 mA)

The controls interface of a DALI ballast normally sources 2 mA, with 64 individual addresses this will source 128 mA. The remaining 72 mA can be used to power other DALI controls without an internal power supply such as the DALI GC and DALI SC.

Installation

- DALI signals are not SELV. Therefore the same procedures should be applied as working with mains voltage.
- Individual DALI circuits must not exceed 200 mA.
- The maximum cable length of the DALI signal wires must not exceed 300 m or drop more than 2 V on the signal line voltage.
- 5-year guarantee



Circuit diagram

Glow-wire test

according to EN 60598-1 passed.

DALI standard

DALI PS is designed to supply control gear with DALI standard IEC 60929 (DALI V0) and IEC 62386 (DALI V1).

1033444
20 – 240
50/60
4
DALI
200
0 – 50





