
K (E

PCA 3/14 T5 EXCEL one4all / 4/14 T5 EXCEL one4all 220–240 V 50/60/0 Hz, dimmable PCA 3/18 EXCEL one4all / 4/18 EXCEL one4all 220–240 V 50/60/0 Hz, dimmable





- dimming range from 10-100 %
- lamp start at 10 %
- lamp friendly warm start within 1.5 s with AC and 0.6 s with DC
- switch via the mains or with digital control signal
- dimming which is comfortable to the eye
- disturbance free precise control with a digital signal (DSI), switchDIM or DALI (digital addressable lighting interface)
- error feed back and programmable features in both DALI and DSI mode
- integrated SMART interface

- fully electronic lamp management and digital communication with ASIC and µC
- constant light output independent of fluctuating supply voltage
- DC operation in emergency lighting installations to VDE 0108
- safe shutdown of defective lamps
- safe shutdown of lamps at end of life (rectifying effect)
- automatic restart after lamp replacement
- operating frequency ~40–100 kHz

Packaging:

box of 20 30 boxes/pallet 600 pieces/pallet

Certified:

BAR

EN 55015 EN 55022 EN 60929 EN 61000-3-2 EN 61347-2-3 EN 61547 in accordance with VDE 0108

Lamp		Ballast										
watt-	length	type	article	length	fixing	weight	circuit	lamp	current	λ	tc point	temperature
age			number	L	centres		power	power	at 230V/50Hz	at 230V/50Hz		range
W			mm	D mm	kg	W3	W 3	A 3		°C	°C	
3x14	550	PCA 3/14 T5 EXCEL 220-240V 50/60/0Hz	22086658	360	340-350	0.38	51.6	3x14	0.23	0.98	80	$+10 \rightarrow +50$ (1)
4x14	550	PCA 4/14 T5 EXCEL 220-240V 50/60/0Hz	22086677	360	340-350	0.40	66.5	4x14	0.32	0.98	80	$+10 \rightarrow +60$ (1)
3x18	590	PCA 3/18 EXCEL 220-240V 50/60/0Hz	22086715	360	340-350	0.38	57.7	3x16	0.26	0.97	75	-25 → +50@
4x18	590	PCA 4/18 EXCEL 220-240V 50/60/0Hz	22086699	360	340-350	0.40	77.5	4x16	0.34	0.99	80	-25 → +60@

(1) dimming to 10 % between 10 $^{\circ}\mathrm{C}$ to ta max.

② dimming to 10 % between 0 °C to ta max.

③ valid at 100 % light output

Lamp starting characteristics: Warm start	Mains currents in DC operation:	Mains current at	Mains current at				
Starting time 1.5 s with AC	Ballast	$U_n = 220 \text{ VDC}$	$U_{\rm II} = 240 \text{ VDC}$				
Starting time 1.5 s with AC	Type PCA 3/14 T5 EXCEL 220–240V 50/60/0Hz	0.19 A	0.17 A				
0							
Start at any dimming level	PCA 3/18 EXCEL 220–240V 50/60/0Hz	0.21 A	0.19 A				
	PCA 4/14 T5 EXCEL 220–240V 50/60/0Hz	0.25 A	0.23 A				
	PCA 4/18 EXCEL 220-240V 50/60/0Hz	0.27 A	0.25 A				
AC operation: Mains voltage 220–240 V 50/60 Hz 198–264 V 50/60 Hz including safety tolerance (±10 %) 202–254 V 50/60 Hz including performance tolerance (+6 % / -8 %)	Light output level in DC operation: Programmable from 10 % to 70 % Programming by extended DSI signal (16 bit) Default value is 70 % In DC operation dimming is not possible						
DC operation:	Ballast lumen factor AC operation (AC-BLF) EN 60929 8.1:						
220–240 V 0 Hz	Ballast	AC-BLF at					
198–280 V 0 Hz certain lamp start	Туре	Un = 230 VAC					
176–280 V 0 Hz operating range	PCA 3/14 T5 EXCEL 220–240V 50/60/0Hz	0.98					
Use in emergency lighting installations	PCA 3/18 EXCEL 220-240V 50/60/0Hz	1.01					
according to VDE 0108 or for emergency	PCA 4/14 T5 EXCEL 220–240V 50/60/0Hz	1.02					
luminaires according to EN 61347-2-3 appendix J.	PCA 4/18 EXCEL 220–240V 50/60/0Hz	1.03					
Temperature range: • PCA 3/14 EXCEL / PCA 4/14 EXCEL: Dimming operation (100 % to 10 %) and 100 %	The ballast lumen factor for AC operation (AC-BL The ballast lumen factor for DC operation (DC-BL of the ballasts (default value is 70 %) will be sma	.F) on the basis of an auto	omatic power reduction				

Dimming operation (100 % to 10 %) and 100 % operation from 10 °C to maximum permissible ambient temperature.

• PCA 3/18 EXCEL / PCA 4/18 EXCEL: Dimming operation (100 % to 10 %) from 0 °C and 100 % operation from -25 °C to maximum permissible ambient temperature.

Harmonic distortion in the mains supply (at 220 V/50 Hz):

range (198-280 VDC).

Ballast						
Туре	THD	3	5	7	9	11
PCA 3/14 T5 EXCEL 220-240V 50/60/0Hz	8.6	8.0	2.7	1.9	1.5	1.2
PCA 3/18 EXCEL 220-240V 50/60/0Hz	9.5	8.8	3.1	2.0	1.4	1.1
PCA 4/14 T5 EXCEL 220-240V 50/60/0Hz	8.1	7.5	2.6	1.6	1.1	0.7
PCA 4/18 EXCEL 220-240V 50/60/0Hz	7.6	7.0	2.6	1.7	1.1	0.7



Dimming:

Dimming range 10 % to 100 % Digital control with:

- DSI signal: 8 bit Manchester Code Maximum speed 10 % to 100 % in 0.9 s
- DALI signal: 16 bit Manchester Code Maximum speed 10 % to 100 % in 0.35 s Programmable parameter: Minimum dimming level Maximum dimming level Default minimum = 10 % Programmable range 10 % \leq MIN \leq 49 % Default maximum = 100 % Programmable range 100 % \geq MAX \geq 50 %

Dimming curve that is friendly to the eye.

Control input (DA/D1, DA/D2):

Digital DALI/DSI signal or switchDIM can be wired on the same terminals (DA/D1 and DA/D2).

Digital signal DALI/DSI:

The control input is non-polar and protected against accidental connection with a mains voltage up to 264 V. The control signal is not SELV. Control cable should be installed in accordance to the requirements of low voltage installations.

Different functions depending on each control module.

SMART interface:

An additional interface for the direct connection of the SMART-LS light sensor. The sensor registers actual ambient light and maintains the individually defined lux level.

After every mains reset the SMART interface automatically checks for an installed sensor. With the sensor installed the PCA EXCEL automatically runs in the constant lux level mode.


ON/OFF-Switch via mains, switchDIM or DALI/DSI signal.


DALI/DSI signal = 0 switches off, DALI/DSI signal \geq 1 switches on. Dimming with DALI or a DSI signal with the SMART-LS installed is not possible. switchDIM enables a temporary change of light level.

The installation of the two wire bus is according to the appropriate low voltage regulations.

Dimming characteristics PCA EXCEL

Digital dimming value







Integrated switchDIM function allows a direct connection of a push to make switch for dimming and switching.

Brief push (< 0.6 s) switches ballast ON and OFF. The ballasts switch-ON at light level set at switch-OFF.

When the push to make switch is held, PCA ballasts are dimmed. After repush the PCA is dimmed in the opposite direction.

In installations with PCAs with different dimming levels or opposite dimming directions (e.g. after a system extension), all PCAs can be synchronized to 50 % dimming level by a 10 s push.


Use of push to make switch with indicator lamp is not permitted.

switchDIM is a very simple tool for controlling ballasts with conventional momentary-action switches or motion sensors.


To ensure correct operation a sinusoidal mains voltage with a frequency of 50 Hz or 60 Hz is required at the control input.

Special attention must be paid to achieving clear zero crossings. Serious mains faults may impair the operation of switchDIM.


Energy Savings PCA EXCEL








DALI PCA EXCEL one4all



DSI PCA EXCEL one4all



switchDIM PCA EXCEL one4all

Loading of automatic circuit breakers:


Automatic circuit breaker type C16 B10 B16 C10 C13 C20 B13 B20 Installation \emptyset 1.5 mm² 1.5 mm² 1.5 mm² 2.5 mm² 1.5 mm² 1.5 mm² 1.5 mm² 2.5 mm² PCA 3/14 T5 EXCEL 16 26 34 42 8 13 17 21 PCA 3/18 EXCEL 16 18 24 30 8 9 12 15 PCA 4/14 T5 EXCEL 16 24 34 38 8 12 17 19 PCA 4/18 FXCFI 12 16 24 28 6 8 12 14

Installation instructions:

Wiring type and cross section:

The wiring can be solid cable with a cross section of 0.5 to 1.5 mm^2 for push terminal and 0.5 mm^2 for concut terminal. For the push-wire connection you have to strip the insulation (7.5–8.5 mm).

$U_{out} = 400 \ V \ 400$



Wiring advice:

The lead length is dependent on the capacitance of the cable.


Ballast	Terminal	Maximum capacitance allowed			
Туре	Cold	Hot	Cold	Hot	
PCA 3/xx EXCEL	5, 6, 7, 8, 11, 12	9, 10	200 pF	100 pF	
PCA 4/xx EXCEL	5, 6, 7, 8, 11, 12, 13, 14	9, 10, 15, 16	200 pF	100 pF	

With standard solid wire 0.5/0.75 mm² the capacitance of the lead is 30–80 pF/m. This value is influenced by the way the wiring is made.

Lamp connection should be made with

symmetrical wiring.

Hot leads (9, 10, 15, 16) and cold leads (5, 6, 7, 8, 11, 12, 13, 14) should be separated as much as possible.




RFI:

- Connection to the lamps of the hot leads must be kept as short as possible
- Mains leads should be kept apart from lamp leads (ideally 5–10 cm distance)
- Do not run mains leads adjacent to the electronic ballast
- Twist the lamp leads
- Keep the distance of lamp leads from the metal work as large as possible
- Ballast must be earthed
- Mains wiring to be twisted when through wiringKeep the mains leads inside the luminaire as
- short as possible

Important advise:

- When using two or more dimmable ballasts in one luminaire with separate dimming controls, the lamp leads must be kept separate
- All lamps must have the same length lead

** digital signal (DALI/DSI) or switchDIM PCA EXCEL one4all 3/14 W, 3/18 W



- * leads 9, 10, 15, 16: keep wires short, max. 1.0 m
- leads 5, 6, 7, 8, 11, 12, 13, 14: max. 2.0 m; ballast must be earthed * * digital signal (DALI/DSI) or switch $\rm DIM$

PCA EXCEL one4all 4/14 W, 4/18 W

