
PCA T5 EXCEL one4all 14-35 W 220-240 V 50/60/0 Hz, dimmable







- dimming range from 1-100 %
- lamp start at 1 % possible
- lamp friendly warm start within 1.5 s with AC and 0.6 s with DC
- switch via the mains or with digital control signal
- dimming which is comfortable to the eye
- disturbance free precise control with a digital signal (DSI), switchDIM or DALI (digital addressable lighting interface)
- error feed back and programmable features in both DALI and DSI mode
- integrated SMART interface

- fully electronic lamp management and digital communication with ASIC and µC
- constant light output independent of fluctuating supply voltage
- DC operation in emergency lighting
 installations to VDE 0109
- installations to VDE 0108
- safe shutdown of defective lampssafe shutdown of lamps at end of life
- (rectifying effect)automatic restart after lamp replacement
- operating frequency ~40–100 kHz

Packaging:

box of 25 28 boxes/pallet 700 pieces/pallet

Certified:

EN 55015 EN 55022 EN 60929 EN 61000-3-2 EN 61347-2-3 EN 61547 in accordance with VDE 0108

Lamp		Ballast										
watt-	length	type	article	length	fixing	weight	circuit	lamp	current	λ	tc point	temperature
age			number	L	centres		power	power	at 230V/50Hz	at 230V/50Hz		range
W			mm	D mm	kg	W©	W 2	A 2		°C	°C	
14	549	PCA 1/14 T5 EXCEL 220/240V 50/60/0Hz	22084884	360	350	0.32	17.8	14	0.09	0.92	70	$+10 \rightarrow +60$
2x14	549	PCA 2/14 T5 EXCEL 220/240V 50/60/0Hz	22084890	360	350	0.36	35.6	2x14	0.16	0.97	80	$+10 \rightarrow +60$
21	849	PCA 1/21 T5 EXCEL 220/240V 50/60/0Hz	22084907	360	350	0.32	25.1	21	0.12	0.95	65	$+10 \rightarrow +60$
2x21	849	PCA 2/21 T5 EXCEL 220/240V 50/60/0Hz	22084916	360	350	0.36	47.7	2x21	0.22	0.98	70	$+10 \rightarrow +60$
28	1149	PCA 1/28 T5 EXCEL 220/240V 50/60/0Hz	22084540	360	350	0.32	32	28	0.15	0.96	70	$+10 \rightarrow +60$
2x28	1149	PCA 2/28 T5 EXCEL 220/240V 50/60/0Hz	22084556	360	350	0.36	61	2x28	0.28	0.98	75	$+10 \rightarrow +60$
35	1449	PCA 1/35 T5 EXCEL 220/240V 50/60/0Hz	22084569	360	350	0.32	38	34	0.17	0.97	75	$+10 \rightarrow +60$
2x35	1449	PCA 2/35 T5 EXCEL 220/240V 50/60/0Hz	22084575	360	350	0.36	75	2x34	0.32	0.98	85	$+10 \rightarrow +60$

① dimming to 1 % between 10 °C to ta max.

2 valid at 100 % light output



Lamp starting characteristics:

Warm start Starting time 1.5 s with AC Starting time 0.6 s with DC Start at any dimming level

AC operation:

Mains voltage 220–240 V 50/60 Hz 198–264 V 50/60 Hz including safety tolerance (±10 %) 202–254 V 50/60 Hz including performance tolerance (+6 % / -8 %)

DC operation:

220–240 V 0 Hz 198–280 V 0 Hz certain lamp start 176–280 V 0 Hz operating range Use in emergency lighting installations according to VDE 0108 or for emergency luminaires according to EN 61347-2-3 appendix J.

Temperature range:

Dimming range 100 % to 1 % from 10 °C to maximum permissible ambient temperature ta.

Mains currents in DC operation:

Ballast	Mains current at	Mains current at
Туре	$U_n = 220 \text{ VDC}$	$U_n = 240 \text{ VDC}$
PCA 1/14 T5 EXCEL 220-240V 50/60/0Hz	0.07 A	0.06 A
PCA 1/21 T5 EXCEL 220-240V 50/60/0Hz	0.10 A	0.09 A
PCA 1/28 T5 EXCEL 220-240V 50/60/0Hz	0.11 A	0.10 A
PCA 1/35 T5 EXCEL 220-240V 50/60/0Hz	0.14 A	0.13 A
PCA 2/14 T5 EXCEL 220-240V 50/60/0Hz	0.12 A	0.11 A
PCA 2/21 T5 EXCEL 220-240V 50/60/0Hz	0.18 A	0.16 A
PCA 2/28 T5 EXCEL 220-240V 50/60/0Hz	0.21 A	0.20 A
PCA 2/35 T5 EXCEL 220-240V 50/60/0Hz	0.27 A	0.25 A

Light output level in DC operation:

Programmable from 1 % to 70 % Programming by extended DSI signal (16 bit) Default value is 70 % In DC operation dimming is not possible

Ballast lumen factor AC operation (AC-BLF) EN 60929 8.1:

Ballast	AC-BLF at
Туре	$U_n = 230 \text{ VAC}$
PCA 1/14 T5 EXCEL 220-240V 50/60/0Hz	1.05
PCA 1/21 T5 EXCEL 220-240V 50/60/0Hz	1.00
PCA 1/28 T5 EXCEL 220-240V 50/60/0Hz	0.99
PCA 1/35 T5 EXCEL 220-240V 50/60/0Hz	1.00
PCA 2/14 T5 EXCEL 220-240V 50/60/0Hz	1.05
PCA 2/21 T5 EXCEL 220-240V 50/60/0Hz	0.98
PCA 2/28 T5 EXCEL 220-240V 50/60/0Hz	0.98
PCA 2/35 T5 EXCEL 220-240V 50/60/0Hz	0.98

The ballast lumen factor for AC operation (AC-BLF) does not alter from $U_n = 198$ VAC to $U_n = 254$ VAC.

The ballast lumen factor for DC operation (DC-BLF) on the basis of an automatic power reduction of the ballasts (default value is 70 %) will be smaller than AC. It does not alter in the DC operating range (198–280 VDC).

Harmonic distortion in the mains supply (at 220 V/50 Hz):

Ballast

Туре	THD	3	5	7	9	11
PCA 1/14 T5 EXCEL 220-240V 50/60/0Hz	9.0	8.6	2.3	1.6	1.3	1.0
PCA 1/21 T5 EXCEL 220-240V 50/60/0Hz	8.0	7.8	1.3	0.9	0.6	0.5
PCA 1/28 T5 EXCEL 220-240V 50/60/0Hz	12.4	11.6	3.7	2.1	1.5	1.1
PCA 1/35 T5 EXCEL 220-240V 50/60/0Hz	8.1	7.8	1.8	1.2	0.8	0.7
PCA 2/14 T5 EXCEL 220-240V 50/60/0Hz	10.6	10.3	2.2	1.3	1.0	0.8
PCA 2/21 T5 EXCEL 220-240V 50/60/0Hz	9.7	9.3	2.3	1.3	1.0	0.8
PCA 2/28 T5 EXCEL 220-240V 50/60/0Hz	6.0	6.0	0.8	0.4	0.3	0.3
PCA 2/35 T5 EXCEL 220-240V 50/60/0Hz	5.3	5.0	1.6	1.1	0.8	0.6



Dimming:

Dimming range 1 % to 100 % Digital control with:

- DSI signal: 8 bit Manchester Code Maximum speed 1 % to 100 % in 1.4 s
- DALI signal: 16 bit Manchester Code Maximum speed 1 % to 100 % in 0.5 s Programmable parameter: Minimum dimming level Maximum dimming level Default minimum = 1 % Programmable range 1 % \leq MIN \leq 49 % Default maximum = 100 % Programmable range 100 % \geq MAX \geq 50 %

Dimming curve that is friendly to the eye.

Control input (DA/D1, DA/D2):

Digital DALI/DSI signal or switchDIM can be wired on the same terminals (DA/D1 and DA/D2).

Digital signal DALI/DSI:

The control input is non-polar and protected against accidental connection with a mains voltage up to 264 V. The control signal is not SELV. Control cable should be installed in accordance to the requirements of low voltage installations.

Different functions depending on each module.

SMART interface:

An additional interface for the direct connection of the SMART-LS light sensor. The sensor registers actual ambient light and maintains the individually defined lux level.

After every mains reset the SMART interface automatically checks for an installed sensor. With the sensor installed the PCA EXCEL automatically runs in the constant lux level mode.

ON/OFF-Switch via mains, switchDIM or DALI/DSI signal.

DALI/DSI signal = 0 switches off,


DALI/DSI signal \geq 1 switches on.


Dimming with DALI or a DSI signal with the SMART-LS installed is not possible. switchDIM enables a temporary change of light level.

The installation of the two wire bus is according to the appropriate low voltage regulations.

Dimming characteristics PCA EXCEL

Digital dimming value





switchDIM:

Integrated switchDIM function allows a direct connection of a push to make switch for dimming and switching.

Brief push (< 0.6 s) switches ballast ON and OFF. The ballasts switch-ON at light level set at switch-OFF.

When the push to make switch is held, PCA ballasts are dimmed. After repush the PCA is dimmed in the opposite direction.

In installations with PCAs with different dimming levels or opposite dimming directions (e.g. after a system extension), all PCAs can be synchronized to 50 % dimming level by a 10 s push.

Use of push to make switch with indicator lamp is not permitted.


switchDIM is a very simple tool for controlling ballasts with conventional momentary-action switches or motion sensors.

To ensure correct operation a sinusoidal mains voltage with a frequency of 50 Hz or 60 Hz is required at the control input.


Special attention must be paid to achieving clear zero crossings. Serious mains faults may impair the operation of switchDIM.

Energy Savings PCA EXCEL










DALI PCA T5 EXCEL one4all



DSI PCA T5 EXCEL one4all

switchDIM PCA T5 EXCEL one4all

Loading of automatic circuit breakers:

Automatic circuit								
breaker type	C10	C13	C16	C20	B10	B13	B16	B20
Installation Ø	1.5 mm ²	1.5 mm ²	1.5 mm ²	2.5 mm ²	1.5 mm ²	1.5 mm ²	1.5 mm ²	2.5 mm ²
PCA 1/14 T5 EXCEL	30	50	70	80	15	25	35	40
PCA 1/21 T5 EXCEL	30	50	70	76	15	25	35	38
PCA 1/28 T5 EXCEL	32	50	72	80	16	25	36	40
PCA 1/35 T5 EXCEL	32	50	70	80	16	25	35	40
PCA 2/14 T5 EXCEL	22	32	44	50	11	16	22	25
PCA 2/21 T5 EXCEL	22	32	44	50	11	16	22	25
PCA 2/28 T5 EXCEL	16	22	30	34	8	11	15	17
PCA 2/35 T5 EXCEL	16	22	30	34	8	11	15	17

Q

Installation instructions:

Wiring type and cross section:

The wiring can be solid cable with a cross section of 0.5 to 1.5 mm² for push terminal and 0.5 mm² for concut terminal. For the push-wire connection you have to strip the insulation (7.5-8.5 mm).

Wiring advice:

The lead length is dependent on the capacitance of the cable.

Ballast	Terminal		Maximum capaci	tance allowed
Туре	Cold	Hot	Cold	Hot
PCA 1/xx T5 EXCEL	11, 12	9, 10	200 pF	100 pF
PCA 2/xx T5 EXCEL	11, 12, 13, 14	9, 10, 15, 16	200 pF	100 pF


With standard solid wire 0.5/0.75 mm² the capacitance of the lead is 30-80 pF/m. This value is influenced by the way the wiring is made.


Lamp connection should be made with

symmetrical wiring.

Hot leads (9, 10, 15, 16) and cold leads (11, 12,

13, 14) should be separated as much as possible.





Ballast


Туре	Uout
PCA 1/14 T5 EXCEL 220-240V 50/60/0Hz	250 V 250
PCA 1/21 T5 EXCEL 220-240V 50/60/0Hz	250 V 250
PCA 1/28 T5 EXCEL 220-240V 50/60/0Hz	400 V 400
PCA 1/35 T5 EXCEL 220-240V 50/60/0Hz	450 V 450
PCA 2/14 T5 EXCEL 220-240V 50/60/0Hz	250 V 250
PCA 2/21 T5 EXCEL 220-240V 50/60/0Hz	250 V 250
PCA 2/28 T5 EXCEL 220-240V 50/60/0Hz	400 V 400
PCA 2/35 T5 EXCEL 220-240V 50/60/0Hz	450 V 450

- RFI: · Connection to the lamps of the hot leads must be kept as short as possible
- · Mains leads should be kept apart from lamp leads (ideally 5-10 cm distance)
- Do not run mains leads adjacent to the electronic ballast
- · Twist the lamp leads
- · Keep the distance of lamp leads from the metal work as large as possible
- · Ballast must be earthed
- Mains wiring to be twisted when through wiring
- · Keep the mains leads inside the luminaire as
- short as possible

Important advise:

- When using two or more dimmable ballasts in one luminaire with separate dimming controls, the lamp leads must be kept separate
- · All lamps must have the same length lead

PCA T5 EXCEL one4all 14-35 W



leads 9, 10, 15, 16: keep wires short, max. 1.0 m leads 11, 12, 13, 14: max. 2.0 m; ballast must be earthed digital signal (DSI), DALI or switch**DIM**

PCA T5 EXCEL one4all 2x14-2x35 W