


#### EM converterLED BASIC HP 6/9 W 250 V

BASIC series

#### Product description

- Self contained emergency lighting LED driver for manual testing
- For LED modules with a forward voltage of 48 – 250 V
- Low profile casing (21 x 30 mm cross-section)
- For luminaire installation
- Nominal lifetime up to 100,000 h
- 5 years guarantee (conditions at [www.tridonic.com](http://www.tridonic.com))



#### Properties

- Non maintained operation
- 1 or 3 h rated duration
- Operating time selectable with plug (duration link)
- Compatible with all dimmable and non-dimmable constant current LED driver (see chapter 5.4)
- 3-pole technology: 2-pole LED module changeover and delayed power switching for the LED driver
- Automatic shutdown of output if LED load is out of range
- Constant power output
- Maximum light output for all LED modules
- Electronic charge system
- Deep discharge protection
- Short-circuit-proof battery connection
- Polarity reversal protection for battery provided by 3-pole connector

#### Batteries

- LiFePO<sub>4</sub> batteries with Tridonic LiFeGuard
- High-temperature cells
- 26650 cells
- 4 years design life
- 3 years guarantee
- For battery compatibility refer to chapter „Battery selection“



**Standards**, page 5

**Wiring diagrams and installation examples**, page 6




## EM converterLED BASIC HP 6/9 W 250 V

### BASIC series

#### Technical data

Rated supply voltage	220 – 240 V
AC voltage range	198 – 264 V
Mains frequency	50 / 60 Hz
LED module forward voltage range	48 – 250 V
Output current	see chapter 5.3
Starting time	< 0.5 s from detection of emergency event
Overvoltage protection	320 V (for 48 h)
U-OUT (including open- / short-circuit and double load)	290 V
Max. open circuit voltage	290 V
Battery charging time	24 h <sup>®</sup>
Ambient temperature range $t_a$	-25 ... + 55 °C
Max. casing temperature $t_c$	80 °C
Mains voltage changeover threshold	according to EN 60598-2-22
Mains surge capability (between L – N)	1 kV
Mains surge capability (between L/N – PE)	2 kV
Type of protection	IP20
Lifetime	up to 100,000 h
Guarantee (conditions at <a href="http://www.tridonic.com">www.tridonic.com</a> )	5 years
Dimensions LxWxH	179 x 30 x 21 mm



Note: LED driver supplied with duration link in 3 hours position. Remove duration link for 1 hour duration. Duration link must be set before battery and mains connection.

#### Ordering data

Type <sup>①</sup>	Article number	Rated duration	Packaging, carton	Packaging, pallet	Weight per pc.
EMcLED BASIC HP 6W 250V	89800829	1/3 h	10 pc(s).	1,600 pc(s).	0.07 kg
EMcLED BASIC HP 9W 250V	89800831	1/3 h	10 pc(s).	1,600 pc(s).	0.07 kg

#### Specific technical data

Type	Battery technology	Rated duration	Typ. $\lambda$ (at 230 V, 50 Hz)	Typ. output power P emergency	Mains current in charging operation			Rated power in charging operation		
					Initial charge	Fast recharge	Trickle charge <sup>®</sup>	Initial charge	Fast recharge	Trickle charge <sup>®</sup>
EMcLED BASIC HP 6W 250V	LiFePO <sub>4</sub>	1 h	0.65C	6 W	32 mA	32 mA	32 / 12 mA	4.8 W	4.8 W	4.8 / 1.4 W
		3 h	0.65C	6 W	32 mA	32 mA	32 / 12 mA	4.8 W	4.8 W	4.8 / 1.4 W
EMcLED BASIC HP 9W 250V	LiFePO <sub>4</sub>	1 h	0.70C	9 W	32 mA	32 mA	32 / 12 mA	4.8 W	4.8 W	4.8 / 1.4 W
		3 h	0.70C	9 W	40 mA	40 mA	40 / 12 mA	6.2 W	6.2 W	6.2 / 1.4 W

<sup>①</sup> EM = Emergency

<sup>®</sup> 16 h battery charging time for 2 h emergency lighting function according to AS 2293.

<sup>®</sup> Voltage dependent constant current charging is used.







ACCESSORIES

EMcLED Strain-relief set 240x43x30mm

Product description

- Optional strain-relief set for independent applications
- Transforms the LED driver into a fully class II compatible LED driver (e.g. ceiling installation)
- Easy and tool-free mounting to the LED driver, screwless cable-clamp channels with strain-relief (240 x 43 x 30 mm)



Permissible cable jacket diameter 2.2 – 9 mm

Ordering data

Type	Article number	Packaging, carton	Packaging, pallet	Weight per pc.
EMcLED SR	28003813	10 pc(s).	1,260 pc(s).	0.08 kg

RoHS

ACCESSORIES

## Test switch EM3

## Product description

- For connection to the emergency lighting unit
- For checking the device function
- Plug connection
- Dielectric strength: 1,500 V AC for 60 seconds



## Ordering data

Type	Article number	Packaging, bag	Packaging, carton	Weight per pc.
Test switch EM 3	89899956	25 pc(s).	200 pc(s).	0.013 kg

ACCESSORIES

## Status indication green LED

## Product description

- A green LED indicates that charging current is flowing into the battery
- Plug connection



## Ordering data

Type	Article number	Packaging, bag	Packaging, carton	Weight per pc.
LED EM green, 1.0 m CON	89800269	25 pc(s).	200 pc(s).	0.015 kg
LED EM green, HO 1.0 m CON	89800271	25 pc(s).	200 pc(s).	0.015 kg
LED EM green, 0.6 m CON	89800472	25 pc(s).	200 pc(s).	0.009 kg
LED EM green, HO 0.6 m CON	89800473	25 pc(s).	200 pc(s).	0.009 kg
LED EM green, 0.3 m CON	89800270	25 pc(s).	200 pc(s).	0.005 kg
LED EM green, HO 0.3 m CON	89800272	25 pc(s).	200 pc(s).	0.005 kg

ACCES-  
SORIES

Extension Cable LiFePO4

Product description

- Extension cable for LiFePO<sub>4</sub> batteries
- Cable length 500 mm
- 3-pole plug connection




Ordering data

Type	Article number	Packaging, bag	Packaging, carton	Weight per pc.
EXTENSION CABLE LiFePO4 500mm	28002461	10 pc(s).	200 pc(s).	0.01 kg

## 1. Standards

- EN 61347-1
- EN 61347-2-13
- EN 61347-2-7
- EN 55015
- EN 61000-3-2
- EN 61000-3-3
- EN 61547
- EN 60068-2-64
- EN 60068-2-29
- EN 60068-2-30
- EN 62384
- according to EN 50172
- according to EN 60598-2-22

Meaning of marking 

Double or reinforced insulation for built-in electronic LED drivers. The control gear relies upon the luminaire enclosure for protection against accidental contact with live parts.

### 1.1 Glow-wire test

according to EN 61347-1 with increased temperature of 850 °C passed.

### 1.2 Insulation and electric strength testing of luminaires

Electronic LED-drivers can be damaged by high voltage. This has to be considered during the routine testing of the luminaires in production.

According to IEC 60598-1 Annex Q (informative only!) or ENEC 303-Annex A, each luminaire should be submitted to an insulation test with 500 V<sub>dc</sub> for 1 second. This test voltage should be connected between the interconnected phase and neutral terminals and the earth terminal. The insulation resistance must be at least 2 MΩ.

As an alternative, IEC 60598-1 Annex Q describes a test of the electrical strength with 1,500 V<sub>AC</sub> (or 1,414 x 1,500 V<sub>DC</sub>). To avoid damage to the electronic devices this test **must not be conducted**.

## 2. Thermal details and lifetime

### 2.1 Lifetime

Average lifetime 50,000 hours under rated conditions with a failure rate of less than 10 %. Average failure rate of 0.2 % per 1000 operating hours.

#### Expected lifetime

EMcLED BASIC HP 6W 250V	t <sub>c</sub>	70 °C	75 °C	80 °C
	lifetime	> 100,000 h	> 100,000 h	> 100,000 h
EMcLED BASIC HP 9W 250V	t <sub>c</sub>	70 °C	75 °C	80 °C
	lifetime	> 100,000 h	> 100,000 h	93,000 h

The emergency lighting LED driver is designed for a lifetime stated above under reference conditions and with a failure probability of less than 10 %.

The relation of t<sub>c</sub> to t<sub>a</sub> temperature depends also on the luminaire design. If the measured t<sub>c</sub> temperature is approx. 5 K below t<sub>c</sub> max., t<sub>a</sub> temperature should be checked and eventually critical components (e.g. ELCAP) measured. Detailed information on request.

## 3. Installation / Wiring


### 3.1 Wiring diagram

One or more LED modules with a total forward voltage of 48 to 250 V can be connected to the EMcLED module. These LED module(s), marked with "Emergency" are operated in emergency mode from the associated battery. In normal mains mode all LED modules are operated by the LED driver from the mains supply.


Use of the test switch:

For checking the device function press the test switch for a minimum of 3 seconds.


### EM converterLED BASIC with one LED module for non-maintained emergency operation



### EM converterLED BASIC with a standard LED driver and one LED module for mains and emergency operation




### EM converterLED BASIC with a standard LED driver and series operation of LED modules



One LED module is operated in emergency mode.  
All LED modules are operated in mains mode.

### EM converterLED BASIC with a standard LED driver and parallel operation of LED modules




One LED module is operated in emergency mode.  
All LED modules are operated in mains mode.

### 3.2 Wiring type and cross section


Solid wire with a cross section of 0.5 – 1.5 mm<sup>2</sup>. Strip 8 – 9 mm of insulation from the cables to ensure perfect operation of terminals.

Wiring: LED module/LED driver/supply




### 3.3 Battery connection


LiFePO<sub>4</sub>: Direct connection



LiFePO<sub>4</sub>: Connection with extension



### 3.4 Loose wiring



Loosen wire through twisting and pulling or using a Ø 1 mm release tool

### 3.5 Wiring guidelines

- The output to the LED is DC but has high frequency content, which should be considered for good EMC compliance.
- Separate LED leads from the mains and DALI connections and wiring for good EMC performance.
- Maximum lead length on the LED terminals is 3 m. For a good EMC performance keep the LED wiring as short as possible.
- Route the secondary wires (LED module) in parallel to ensure good EMC performance.
- Maximum lead length for the Test switch and Indicator LED connection is 1 m. Separate the test switch and Indicator LED wiring from the LED leads to prevent noise coupling.
- Battery leads are specified with 0.5 mm cross section and a length of 0.8 m
- Protect the wiring against short circuits to earth (sharp edged metal parts, metal cable clips, louver, etc.) to avoid the damage of the control gear.

To ensure that a luminaire containing LED emergency units complies with EN 55015 for radio frequency conducted interference in both normal and emergency mode it is essential to follow good practice in the wiring layout.

Within the luminaire route the switched and unswitched 50 Hz supply wiring as short as possible and keep it as far away as possible from the LED leads. Through wiring may affect the EMC performance of the luminaire.

Do not exceed the max. length of LED leads to the LED module. Note that the length of the EM converterLED leads to the LED module is added to the length of the leads from the LED driver to the EM converterLED module when considering the max. permitted lead length of the LED driver.

### 3.6 Maximum lead length

LED	3 m (6 m loop) <sup>①</sup>
Status indication LED	1 m
Batteries	0.8 m

### 3.7 Use of different phases

The use of different phases for switched line and unswitched line is allowed. When using different phases, the unswitched line must fail if the switched line fails. This is required to assure correct switching into emergency mode. It can be realised with a relay.

## 4. Mechanical values

### 4.1 Housing properties

- Casing manufactured from polycarbonate.
- Type of protection: IP20
- Max. torque at the mounting screws: 0.8 Nm

### 4.2 Mechanical data accessories

LED status indicator

- Green
- Mounting hole 6.5 mm diameter, 1 – 1.6 mm thickness
- Lead length 0.3 m / 0.6 m / 1.0 m
- Insulation rating: 90 °C
- Plug connection

Test switch

- Mounting hole 7.0 mm diameter
- Lead length 0.55 m
- Plug connection

Battery connection

- Plug connection 0.3 m
- Extension 0.5 m

## 5. Electrical values

### 5.1 Maximum loading of automatic circuit breakers

Automatic circuit breaker type	B10	B13	B16	B20	C10	C13	C16	C20	Inrush current	
Installation Ø	1.5 mm <sup>2</sup>	1.5 mm <sup>2</sup>	1.5 mm <sup>2</sup>	2.5 mm <sup>2</sup>	1.5 mm <sup>2</sup>	1.5 mm <sup>2</sup>	1.5 mm <sup>2</sup>	2.5 mm <sup>2</sup>	I <sub>max</sub>	time
<b>EMcLED BASIC</b>	90	130	130	130	180	260	260	260	10 A	120 µs

### 5.2 Insulation matrix

	Mains	Switched Live	Battery, LED, Test switch, Indicator LED	LED driver
<b>Mains</b>	–	•	••	•
<b>Switched Live</b>	•	–	••	•
<b>Battery, LED, Test switch, Indicator LED</b>	••	••	–	–
<b>LED driver</b>	•	•	–	–

• Represents basic insulation

•• Represents double or reinforced insulation

When using a non-SELV LED driver insulate the battery, LED, test switch and indicator LED in the luminaire according to the U-OUT rating of the LED driver.

DALI terminals are not SELV. Wire the terminals in accordance with the requirements of low voltage installations.

### 5.3 Typ. LED current/voltage characteristics

The LED current in emergency mode is automatically adjusted by the EM converterLED module based on the total forward voltage of the LED modules connected and the associated battery. The start of the LED in emergency mode does not result in a current peak.

EMcLED BASIC HP 6W 250V

Article number: 89800829

1 h application

LiFePO<sub>4</sub> battery 2S1P, 6.4 V battery voltage

3 h application

LiFePO<sub>4</sub> battery 2S2P, 6.4 V battery voltage

EMcLED BASIC HP 9W 250V



Article number: 89800831

1 h application

LiFePO<sub>4</sub> battery 2S1P, 6.4 V battery voltage

3 h application

LiFePO<sub>4</sub> battery 3S2P, 9.6 V battery voltage



———— Max. LED current at nominal battery voltage

- - - - - Min. LED current at nominal battery voltage

## 5.4 LED driver compatibility



The EM converterLED emergency unit use 3 pole technology and is compatible with most LED drivers on the market, however it is important to check that the rating of the LED driver does not exceed the values specified below:

- The max. allowed output current rating of the associated LED driver is 2 A peak (current rating of the terminals of EM converterLED)
- The max. allowed inrush current rating of the associated LED driver is 60 A peak for 1 ms or 120 A for 250  $\mu$ s (inrush current rating of switching relay of EM converterLED)
- The max. allowed output voltage (U-OUT) of the associated LED driver applied to the EM converterLED output is 500 V (voltage withstand between adjacent contact of the single switching relay of the EM converterLED)
- The max. allowed LED load of the associated LED driver is 300 W in operation. The load must be an LED module.

Check compatibility with short function tests (duration of several seconds).

## 6. Functions

### 6.1 Duration link selection

Duration	Usage duration link
3 h	 With link
1 h	 Without link

Emergency lighting LED driver supplied with duration link in 3 hours position.

The position of the link will only be read on first power up. If it is changed afterwards both the battery and mains supply must be disconnected for 10 seconds to enable the EM converterLED to read the new link position on reconnection of the battery and mains. It will lead to a false battery failure indication if the link is changed after installation without this reset.

### 6.2 Status indication LED

System status is indicated by a green LED.

Note:

The status indication LED switches off if the battery does not reach the full capacity (3.6V battery voltage) within 20 – 24 hours.

If this occurs disconnect the mains voltage and operate the device in emergency mode for approximately one hour. Afterwards apply the mains voltage again and recharge the battery for 24 hours.

If the failure occurs again replace the battery.

## 7. Battery data

### 7.1 Battery selection

EM converterLED BASIC, 1 / 3 h

		Type	EMcLED BASIC HP 6W 250V		EMcLED BASIC HP 9W 250V	
		Article no.	89800829		89800831	
		Duration	1 h	3 h	1 h	3 h
Technology and Design capacity	Number of cells	Type	Article no.			
			Assignable batteries			
LiFePO <sub>4</sub> 3,6 Ah 26650 cells	Soft pack	2 x 1	ACCU-LiFePO <sub>4</sub> 3.6Ah 2A 2S1P CON	28003814	•	•
	Soft pack	2 x 2	ACCU-LiFePO <sub>4</sub> 7.2Ah 4A 2S2P CON	28003815	•	•
	Soft pack	3 x 2	ACCU-LiFePO <sub>4</sub> 7.2Ah 6A 3S2P CON	28003816	•	•
	Hard pack	2 x 2	PACK-LiFePO <sub>4</sub> 7.2Ah 2S2P CON	28003809	•	•
	Hard pack	3 x 2	PACK-LiFePO <sub>4</sub> 7.2Ah 3S2P CON	28003810	•	•

### 7.2 Battery charge / discharge data

EM converterLED BASIC, 1 / 3 h, LiFePO<sub>4</sub>

		Type	EMcLED BASIC HP 6W 250V		EMcLED BASIC HP 9W 250V	
		Article no.	89800829		89800831	
		Duration	1 h	3 h	1 h	3 h
Battery charge time	Initial charge	24 h				
	Fast recharge	24 h				
	Trickle charge	continuously and battery voltage controlled				
Charging current	Initial charge	350 – 390 mA	350 – 390 mA	350 – 390 mA	350 – 390 mA	350 – 390 mA
	Fast recharge	350 – 390 mA	350 – 390 mA	350 – 390 mA	350 – 390 mA	350 – 390 mA
	Trickle charge <sup>①</sup>	350 – 390 mA / 0 mA	350 – 390 mA / 0 mA	350 – 390 mA / 0 mA	350 – 390 mA / 0 mA	350 – 390 mA / 0 mA
Discharge current range <sup>②</sup>		885 – 1400 mA	885 – 1400 mA	1,365 – 2,135 mA	925 – 1,340 mA	
Charge voltage range <sup>③</sup>		2.0 – 3.65 V per cell				
Discharge voltage range		3.65 – 2.60 V per cell				

<sup>①</sup> Automatic recharge when battery voltage falls below 3.4 V. Charger off (0 mA) when battery voltage exceeds 3.6 V.

Note: Battery protected against operation at excessive temperatures (charging stopped when battery cell temperature < -5 °C or > 60 °C).

The emergency lighting LED driver will recharge the battery normally after running the test of 61347-2-7 CL 22.3 (abnormal operating conditions).

<sup>②</sup> The battery will not be charged below 2.0 V.

<sup>③</sup> The discharge current varies depending on the battery voltage and the LED voltage to maintain the constant output power.

### 7.3 Accu-LiFePO<sub>4</sub>

#### Capacity 3.6 Ah

International designation	IFpR 27/67
Battery voltage/cell	3.2 V
Cell type	26650
Case temperature range to ensure 4 years design life	+50 °C
Max short term battery case tc point temperature (reduced lifetime)	70 °C
Max. number discharge cycles	50 cycles total
Max. storage time	12 months at +5 °C to +25 °C

Only use Tridonic batteries.

Comply with UN 38.3 and IEC 62133 (safety testing) protected against over charge, over discharge, charging at excessive temperatures, short-circuit and over current.

### 7.4 Safety



#### LiFeGuard

#### 7.4.1 Deep discharge protection

When the battery remains connected without charging for a long period of time after the battery cut off of the driver the battery voltage can still drop. To make sure the cells are not damaged by this voltage drop, the battery protection prevents the battery from further discharge below 2.0 V.

#### 7.4.2 Overcharge protection

In case of an error or the use of a wrong driver the battery gets overcharged. The battery protection will disconnect the battery from the driver at a voltage of 3.9 V. A discharge of the battery is still possible after the protection circuit was triggered to guarantee emergency operation.

#### 7.4.3 Short-circuit protection

In case of a short circuit the battery protection opens the connection to the driver and the output is therefore free of voltage. The output will be reactivated again when the short circuit is removed.

#### 7.4.4 Overtemperature protection

The battery is protected against temporary thermal overheating. If the temperature limit is exceeded the further charging of the battery is no longer possible. The temperature protection is activated below approx. 0 °C and above approx. +60 °C. The discharging of the battery is still possible to guarantee emergency operation.

### 7.5 Wiring batteries

For further information refer to corresponding battery datasheet.

### 7.6 Storage, installation and commissioning

Relevant information about storage conditions, installation and commissioning are provided in the battery datasheets.

## 8. Miscellaneous

### 8.1 Maximum number of switching cycles

EM converterLEDs are tested with 50,000 mains switching cycles of the associated LED driver.

### 8.2 Battery replacement

After a battery replacement and a subsequent full charge cycle (24 h) a duration test is mandatory to prove that with the new battery the rated duration is achieved.

### 8.3 Mains-connected transformers

The EM converterLED does not contain mains-connected windings of transformers.

### 8.4 FELV control terminals



FELV control terminals marked „Risk of electric shock“ are not safe to touch. Insulate circuits connected to any FELV control terminal for the Low Voltage supply voltage of the control gear. Protect terminals connected to the FELV circuit against accidental contact.

### 8.5 Additional information

Additional technical information at [www.tridonic.com](http://www.tridonic.com) → Technical Data

Lifetime declarations are informative and represent no warranty claim. No warranty if device was opened.