connecDIM Gateway G1
Ethernet TCP/IP to DALI

Product description

- Independent lighting control for up to 256 DALI gears on 4 DALI lines
- Can be expanded by connecting multiple gateways on the same network
- Cloud based web interface for configuration and monitoring
- Setup via mobile App or Cloud service
- Connects to Tridonic DALI Interface RS232 PS/S
- Cross DALI line control
- Freely programmable daily scheduling with calendar function
- DALI emergency lighting unit test scheduling and monitoring via the connecDIM Cloud
- 5-year guarantee

Data sheet 01/20-CO075-14

Subject to change without notice. Information provided without guarantee.   www.tridonic.com   1

♻ ◈ ⊕ □ ⚠ CE RoHS

connecDIM Gateway G1

Ethernet TCP/IP to DALI

Technical data

Rated supply voltage DC	9 – 48 V
Power consumption	3.6 W (300 mA @ 12 V DC)
DALI interface RS232 PS/S ports	4 x RJ45 Serial Ports
Ethernet port	1 x 10/100 Mbit/s
Status indicators LED	Power, Ready, Ethernet, Serial Port
Operating Temperature	0 … +70°C
Mounting	Tabs with screw terminals; DIN rail kit available
Casing Material	Fanless metal casing
Type of Protection	IP20

Ordering data

Type	Article number	Packaging carton	Weight per pcs.
connecDIM Gateway G1	**28000966**	1 pc(s).	0.405 kg

Data sheet 01/20-CO075-14

Subject to change without notice. Information provided without guarantee.

www.tridonic.com

2

DALI ⚠ CE

Product description

- Combines interface module and DALI power supply
- Integrated power supply with 240 mA for DALI devices or DALI control modules without power supply
- Interface module for connection of DALI systems with computer or programmable control systems
- For installation in switching cabinets
- 5-year guarantee

Technical data

Rated supply voltage	110 – 240 V
Permitted input voltage	110 – 260 V
Mains frequency	50 / 60 Hz
Power	1 – 6 W
Standby power	1 W
Max. output current, DALI	240 mA
Output voltage	16 V ±5 %
Operating temperature	0 … +50 ℃
Storage temperature	-20 … +60 ℃
Max. casing temperature tc	80 ℃
Permitted relative humidity	10 – 90 %, not condensed
Mounting	DIN rail mounting, 35 mm
Casing material	PC, flame retardant, halogen-free
Type of protection	IP20

Ordering data

Type	Article number	Packaging, carton	Weight per pc.
DALI Interface RS232 PS/S	**28001847**	100 pc(s).	0.09 kg

Specific technical data

Type	Input RS232	DALI output
DALI Interface RS232 PS/S	1	1

Data sheet 01/20-CO075-14

Subject to change without notice. Information provided without guarantee.   www.tridonic.com   3

ACCES-SORIES | **connecDIM RS232 cable**

Product description

- Connection cable 1 m for connection of a DALI Interface RS232 PS/S to the connecDIM Gateway G1
- RJ45 to RJ45
- Transparent connector: connection to connecDIM Gateway G1
- Black connector: connection to DALI Interface RS232 PS/S

Ordering data

Type	Article number	Length	Packaging carton	Weight per pcs.
connecDIM RS232 cable	28000968	1 m	1 pc(s).	0.06 kg

ACCES-SORIES | **connecDIM DIN-RAIL Mounting Kit**

Product description

- DIN-RAIL Mounting Clips to mount the connecDIM Gateway G1 onto a 35 mm DIN-RAIL

Ordering data

Type	Article number	Packaging carton	Weight per pcs.
connecDIM DIN-RAIL Mounting Kit	28000969	1 pc(s).	0.03 kg

Data sheet 01/20-CO075-14

Subject to change without notice. Information provided without guarantee.   www.tridonic.com   4

ACCES-SORIES

mains adapter x-touchPANEL

Product description

- Power supply for the DALI x-touchPANEL and the DALI e-touchPANEL
- The mains adapter is rated at 36 V
- Max. 2 gateways can be connected

Technical data

Rated supply voltage	230 – 240 V
Mains frequency	50 / 60 Hz
Max. power consumption	10 W
Output voltage	36 V
Max. output current	300 mA
Ambient temperature ta	0 ... +50 °C
Type of protection	IP20

Ordering data

Type	Article number	Packaging carton	Weight per pcs.
mains adapter x-touchPANEL	**24166012**	1 pc(s).	0.155 kg

Data sheet 01/20-CO075-14

Subject to change without notice. Information provided without guarantee.   www.tridonic.com   5

1. Standards

EN 61347-1
EN 61347-2-11
EN 60950-1
EN 55022
EN 55015
EN 61547
EN 61000-3-2
EN 61000-3-3
EN 61000-6-2
EN 50581

2. Common

2.1 Overview

The connecDIM system consists of a single four-channel RS232 Ethernet gateway connected to Tridonic DALI Interface RS232 PS/S and a wireless router. This enables 4 x 64 DALI devices to be networked and this DALI circuit to be controlled as a whole, thanks to controllers connected to the DALI circuit with mobile devices (iOS or Android operating system), irrespective of whether T5, T8, LED or Tunable White DALI devices are used. The system can be expanded to more than 4 DALI lines by connecting multiple connecDIM Gateways to the network. This allows local DALI control devices such as DALI XC or DALI MSensors to control multiple devices on multiple DALI lines. The connecDIM system is a solution for providing DALI control over multiple DALI lines.
It also enables DALI system to be commissioned without having to use a laptop or dedicated software.
Two apps are available for the connecDIM System.
connecDIM Architect, commissioning app, available for iOS and connecDIM Lite, end-user app, available for iOS and Android.
Existing DALI applications can be simply upgraded by replacing the DALI power supply with DALI Interface RS232 PS/S and connecting the connecDIM Gateway. If an internet connection is used the system can be easily made available on the connecDIM Cloud.

2.2 Storage of data

The connecDIM system collects data and stores it in the cloud.
Our storage policy is as follows:
• If the connecDIM system is used in combination with emergency applications, these emergency application data will be stored for a maximum of 24 months.
  Data older than 24 months will be automatically deleted.
• All other data collected in the cloud will be stored for 3 months.
  Data older than 3 months will be automatically deleted.

Data integrity in the cloud cannot be guaranteed as bad internet connections and other network anomalies may influence the correctness of the data displayed in the cloud.

2.3 LED

Ready LED
After Power ON, the gateway starts booting. Once the system has booted up, the Ready LED will show solid green.

Link/Act LED
When the Ethernet port is connected to the network, Link/Act will show solid green and if there is traffic on the Ethernet, this LED will flash.

Serial Port LED
These four dual colour LEDs indicate data traffic at the serial ports. When the RXD line is high the green light will be ON and when the TXD line is high the yellow light will be ON.

Power Connector
Connect the 9 to 48 VDC power line to the gateway. If power is being supplied correctly, the power LED will show solid green.

2.4 Device overview

Don't connect
Reset
10/100 Mbp/s Ethernet
9–48 V DC Power
Don't connect

Power LED
System Ready LED
Ethernet LED
Don't connect
Serial Port LED

Linie 1 – Linie 4
Serial Ports

⚠ Reset button will trigger a reboot of the Gateway.
Data stored on the Gateway will not be deleted.

Data sheet 01/20-CO075-14

Subject to change without notice. Information provided without guarantee.   www.tridonic.com   6

3. Interface

3.1 Serial Port

Serial Port Line 1 to Line 4
The four serial ports are configured to RS-232 and can be connected to
TRIDONIC DALI Interface RS232 PS/S. They use RJ45 connectors and the pin
assignment is shown in the following table.

⚠️ Please note that standard patch cables should **not** be used! Refer
also to the product datasheet for TRIDONIC DALI Interface RS232
PS/S. Available online at www.tridonic.com.

Please ensure that the correct RJ45 connector is connected to the gateway
and to the RS232 DALI Interface. The cables supplied are clearly marked with
"BOX" or with different colors. The BOX end (transparent connector) goes
to the gateway and the other end (black connector) goes to DALI Interface
RS232 PS/S.

Gateway (RJ45)		Wiring:	RS232 PS/S (RJ45)	
pin 3	Ground		pin 4	Ground
pin 4	TxD		pin 5	TxD
pin 5	RxD		pin 6	RxD
pin 8	DTR (for supply purpose only)		pin 3	DTR (for supply purpose only)
pin 2	RTS (for supply purpose only)		pin 8	RTS (for supply purpose only)

Gateway   connecDIM RS232 cable   RS232

4. Installation

4.1 Safety instructions

⚠️ The device may only be used for the specified area of application.

Relevant health and safety regulations must be observed.

The voltage supply must be disconnected when the device is being
assembled and installed.

Only qualified personnel may assemble, install and commission the
device.

Do not use DALI Interface RS232 PS/S with any other devices that supply power
(e.g. DALI PS).

Another way to test if another power supplying device is on the DALI signal wire
is to connect:
DALI Interface RS232 PS/S to the DALI signal wire with the mains supply
disconnected. If the power LED and the status LED are on (typically green)
despite no mains supply to DALI Interface RS232 PS/S then another device
is supplying power on the DALI signal wire.

4.2 Wiring examples

Data sheet 01/20-CO075-14

Subject to change without notice. Information provided without guarantee.   www.tridonic.com

8

4.3 Wiring type and cross section

The wiring can be solid wire, stranded wire or stranded wire with end sleeve
with a cross-section of 0.5 mm² to 2.5 mm².

wire preparation:
0.5 – 2.5 mm2

7 – 8 mm

5. Miscellaneous

5.1 Additional information

Additional technical information at www.tridonic.com → Technical Data

Guarantee conditions at www.tridonic.com → Services

Life-time declarations are informative and represent no warranty claim.
No warranty if device was opened.

Data sheet 01/20-CO075-14

Subject to change without notice. Information provided without guarantee.   www.tridonic.com   9